

sign post or pillar





A Various drawing revisions

Testing


Earth electrode mat shall be tested as per BS7671 by an approved method, as stated in section 643.7.2 of the current I.E.T wiring regulations.

Notes

The earth electrode mat and cabling arrangements shall conform to chapter 54 section 542.2-543.4 of the current I.E.T wiring regulations BS7671.

The warning label shall comply with chapter 51 section 514.13 of the current I.E.T wiring regulations BS7671, label to be pillar/column/sign post.

2 bags of Marconite carbon enriched concrete compound are to be used, one to be mixed and set in the base of the excavation and spread evenly across the base of excavation, the earth electrode mat placed in the excavation with the 16mm earth cable connected and ducted to the relevant equipment, then the second bag of mixed Marconite carbon enriched concrete compound installed on the top of the mat. The surface can be relaid once the Marconite carbon encriched concrete compound has set.



AS RC DOK 07/21

Dwn Chk App Date

NTS

Hertfordshire

COUNTY HALL Pegs Lane Hertford, Herts SG13 8DN Phone: 01992 555555

EARTH ELECTRODE MAT